

Certificate of Compliance

Certificate: 1526264 Master Contract: 187963

Project: 2290924 Date Issued: May 25, 2010

Issued to: Mecc Alte S.p.A

Via Roma, 20

I - 36051 Creazzo (VI)

ITALY

The products listed below are eligible to bear the CSA Mark shown



Nico Bos

Issued by: Nico Bos

PRODUCTS

CLASS - 4211 01 - MOTOR AND GENERATORS

Self Regulating Electric Generators, 2 or 4 poles, indoor use continuous duty, flange mounted, three phase, 400/480Vac max., 50/60Hz, insulation Class H; 40°C rated ambient;

Part A

- Series ECO 28, 50Hz, 22 31.5kVA max or 60Hz, 26.5 38kVA max, 2 pole
- Series ECO 31, 50Hz, 44 82kVA max or 60Hz, 53 98,5kVA max, 2 pole
- Series ECO 28, 50Hz, 17 30kVA max or 60Hz, 20,4 36kVA max, 4 pole
- Series ECO 40, 50Hz, 400 680kVA max or 60Hz, 480 816kVA max, 4 pole
- Series ECO43N, 50Hz, 800–1300kVA max or 60Hz, 960 1560kVA max, 4 pole, brushless

<u>Part B</u>

- Series ECSO 28, 50Hz, 22 31.5kVA max or 60Hz, 26.5 38kVA max, 2 pole
- Series ECSO 31, 50Hz, 44 82kVA max or 60Hz, 53–98,5 kVA max, 2 pole
- Series ECSO 28 50Hz, 17 30kVA max or 60Hz, 20,4 36 kVA max, 4 pole
- Series ECSO 32, 50Hz, 31 70kVA max or 60Hz, 37.2 84kVA max, 4 pole

DQD 507 Rev. 2009-09-01 Page 1

Certificate: 1526264 CSA INTERNATIONAL

Master Contract: 187963 **Project:** 2290924 **Date Issued:** May 25, 2010

Part C

Series BTO3, 50Hz, 16–20kVA max or 60Hz, 19.2 – 24kVA max, 2 pole, with brushes

Series BTO3, 50Hz, 7-15kVA max or 60Hz, 8.4 - 18kVA max, 4 pole, with brushes

Part D

- Series ECO3, 50Hz, 8–19kVA max or 60Hz, 9.6 22.8kVA max, 2 pole, brushless.
- Series ECO3 50Hz, 6.5–15kVA max or 60Hz, 7.8 18kVA max, 4 pole, brushless.

Part E

Self Regulating Electric Generators, 4 pole, indoor use continuous duty, flange mounted, three phase, 500/600Vac max., 50/60Hz, insulation Class H; 40°C rated ambient;

- Series ECO 32, 50Hz, 31 70kVA max or 60Hz, 37.2 84kVA max,
- Series ECP 34, 50Hz, 85 150kVA max or 60Hz, 102 180kVA max,
- Series ECO 38, 50Hz, 180 350kVA max or 60Hz, 220 420kVA max,

Part F

Open type self regulating Electric Generators, 2 or 4 pole, indoor use continuous duty, flange mounted, single and three phase, 400/480Vac max., 50/60Hz.

Series Westerberke, single phase, 50/60Hz, 22/26 kVA max; three phase, 50/60Hz, 97.5/117kVA.

Note: The Westerberke series are designed with an open area on the non drive side flange.

This open Area is to be totally covered by the mounting of an other equipment on the generator flange in the final installation.

APPLICABLE REQUIREMENTS

The product, as described in this report, complies with:

CAN/CSA - C22.2 No. 0.4-04 Bonding of electrical equipment

CAN/CSA – C22.2 No. 100-04 **Motors and Generators**

DQD 507 Rev. 2009-09-01



Supplement to Certificate of Compliance

Certificate: 1526264 Master Contract: 187963

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1526264	February 2, 2004	Original Certification CSA Generators 2 and 4 poles; ECO, ECSO, BTO3N,BTO3,ECO3N, ECO3, WESTERBEKE and ECO32, ECO34N, ECO38,
		*this report supersedes previous report - 1109686
1773739	March 22, 2006	Update to report 1526264: change of designation of series ECO34N and ECO38 to ECP34 and ECO38N , due to a different rotor assembly configuration
		Report re-issued
2116488	July 06, 2009	Update to report 1526264: change of power range ratings of series ECO31, ECO28, ECSO31, ECSO28 and ECO3
		Report re-issued
2290924	May 25, 2010	Update to report 1526264:Addition in alternative of digital regulator DSR and optional use Three- Phase interface sensing board IF321.

DQD 507 Rev. 2009-09-01 Page 1